


## SAFE DRINKING WATER CERTIFICATE

No. 15

Dated: 24/01/2026

It is certified that an inspection team headed by **Satya Prakash Azad (Chemist)** (Name of Officers with designation) from **P.H.E.D. Investigation Office** (Name of Department/ Office) inspected the **ST. MARYS SCHOOL, Chakkar Chowk, Kalambabh Road, Muzaffarpur, Bihar 842001** (Name & Address of the school) on 22.01.2026 date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year

Signature with Seal:   
Name : **CHEMIST**  
Designation: **R.W.T.L; MUZAFFARPUR**


To  
The Principal,  
ST. MARYS SCHOOL  
, Chakkar Chowk, Kalambabh Road,  
Muzaffarpur, Bihar 842001

**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**Regional Water Testing Laboratory**

District Name : Muzaffarpur

Month -January 2026

Sl. No.	Block	Panchayat	Village	Ward	Location of Source	pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alk	Fe	So <sub>4</sub>	NO <sub>3</sub>	F	As	MPN	Remarks
1	Mushari	Nagar Nigam	Chakkar Chowk		St Mary School, Kalambag Road	7.26	1	488	306	274	70	23.00	32	280	0.3	15	5	0.3	BDL	NIL	
Acceptable Limit (IS 10500-2012)						6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	75 mg/l	30 mg/l	250 mg/l	200 mg/l	1.0 mg/l	200 mg/l	45 mg/l	1.0 ppm	0.01 ppm	0.01 mg/l	
Permissible Limit in absence of alternate source (IS 10500-2012)						NR	5 NTU	-	2000 mg/l	600 mg/l	200 mg/l	100 mg/l	1000 mg/l	600 mg/l	NR	400 mg/l	NR	1.5 ppm	NR	0.1 mg/l	

  
 Chemist 24/01/26  
**RWTL Muzaffarpur**